



A MAHARASHTRA FIRE SERVICE LICENSE AGENCY

■ Office Address : 30, Vishwakarma Nagar, Line No. 8, Nagpur - 440 027 ■ M : 09503344191 | 8080211425
■ Pune Address : 102, Rajhans Baner Road, Pune. ■ E-mail Address : swastik.firesafe@gmail.com

FORM B

CERTIFICATE

Certified that we have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises.

Building Name "Hilfort Public School" 12, Fuke Patil Marg, Ambazari Road, Near Ram Dwar, Hill Top Layout, Ram Nagar, Nagpur, Maharashtra .

I, further certify that this installation in the above mentioned buildings are maintained in good repair and efficient conditions during the period of 1st of June to 31th of Dec 2023, as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006(Maha III of 2007)

The details of the inspection of Installations carried out by me are mentioned in the report appended herewith in Annexure.

Place : NAGPUR

Date: 17-06-2023

For **SWASTIK ENTERPRISES**

Digitally
signed by
SURAJ
KISHOR FALKE
Date:
2023.12.10
11:39:15
+0530'

Proprietor

Suraj K. Falke

License no. MFS/LA/RF-328/RD-319



Suppliers & Installers of

■ Fire Alarm System ■ Fire Hydrant System ■ Fire Sprinkler System ■ Fire Extinguisher ■ Fire Doors ■ A.M.C.



**SWASTIK
ENTERPRISES**

A MAHARASHTRA FIRE SERVICE LICENSE AGENCY

■ Office Address : 30, Vishwakarma Nagar, Line No. 8, Nagpur - 440 027 ■ M : 09503344191 | 8080211425
 ■ Pune Address : 102, Rajhans Baner Road, Pune. ■ E-mail Address : swastik.firesafe@gmail.com

ANNEXURE

Name of the Building	"Hilfort Public School" Ambazari Road, Ram Nagar, Nagpur		
Classification of building	School	Height of Building	12 mtr
Main Pump	0 lpm	Overhead Tank Cap.	25000 ltr
Standby Pump	0 lpm	Underground Tank Cap.	100000 ltr
Jockey pump	0 lpm	Terrace Pump	1 900 lpm
Pump Electrical Panel		Fire Alarm Panel	1 Nos
Wet Riser/ Down Comer		Number Of Wings	1 Nos
Fire Service Inlet		Court Yard Hydrant	3 NOS
Fire Control Room			

Sr. No.	List Of Equipment					TOTAL	STATUS
		GROUND FLOOR	FIRST FLOOR	SECOND FLOOR	THIRD FLOOR		
1	Floor Area						
2	Hose Reel	0	1	1	1	3	OK
3	Hydrant Valve	1	1	1	1	4	OK
4	RRL Hose with SS couplings	1	1	1	1	4	OK
5	Hose Box	1	1	1	1	4	OK
6	SS Branch pipe	1	1	1	1	4	OK
7	Fire Extinguisher - ABC 6 KG	2	2	2	2	8	OK
8	Fire Extinguisher - CO2 4.5 KG	1	0	0	0	2	OK
11	2 Way inlet	0	0	0	0	1	OK
14	MCP	1	1	1	1	4	OK
15	Hooter	1	1	1	1	4	OK


Place: Nagpur

For SWASTIK ENTERPRISES

Date: 17-06-2023

Digitally signed by
SURAJ KISHOR
FALKE
Date: 2023.12.10
11:38:45 +05'30'

Proprietor
Suraj K. Falke
License no. MFS/LA/RF-328/RD-319



(Handwritten signature)

Suppliers & Installers of

■ Fire Alarm System ■ Fire Hydrant System ■ Fire Sprinkler System ■ Fire Extinguisher ■ Fire Doors ■ A.M.C.